



TOWN OF CLEVELAND

302 East Main Street, Cleveland NC 27013

Maintenance Log

FACILITY NAME:					LOCATION:					
CONTACT:					PHONE:					
DEVICE: INTERCEPTOR() TRAP()										
INTERCEPTOR- DEPTH in. () ; CHECK MONTHLY AFTER APPROVAL; PUMPED QUARTERLY										
Type of service: () Measurement () Pumped & Cleaned () Repair By: _____			Pumped by: _____ _____ _____			Volume pumped & Disposal Site Gal- Site- _____ _____		Comments		
Measurement/Date-										
Week	1	2	3	4	5					
Sludge (Top):										in
Solids (Bottom):										in
Total:										in
Total ÷ Depth x 100=	%	%	%	%	%					%
25% and above must be pumped!!										
TRAP-MUST BE PUMPED AND CLEANED WEEKLY									Comments	
Date	Type of Service () Pump & clean () Repair		Vol. pumped-__ gal. Collection site: _____ By: _____			Collection Vol. Disposed __ gal. Site: _____ By: _____				
	() Pump & clean () Repair		Vol. pumped-__ gal. Collection site: _____ By: _____			Collection Vol. Disposed __ gal. Site: _____ By: _____				
	() Pump & clean () Repair		Vol. pumped-__ gal. Collection site: _____ By: _____			Collection Vol. Disposed __ gal. Site: _____ By: _____				
	() Pump & clean () Repair		Vol. pumped-__ gal. Collection site: _____ By: _____			Collection Vol. Disposed __ gal. Site: _____ By: _____				
	() Pump & clean () Repair		Vol. pumped-__ gal. Collection site: _____ By: _____			Collection Vol. Disposed __ gal. Site: _____ By: _____				